

Laboratory Report

DATE REPORTED: 04/18/2025

CLIENT: Barton Village, Inc.
PROJECT: WSID 5189 DBPWORK ORDER: 2504-09854
DATE RECEIVED: 04/03/2025

001 Site: 112 Municipal Lane (WWTF)

Date Sampled: 4/3/25 Time: 10:00

Facility ID: DS001 Smp Pt: HA001 Categ: GE Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual
HALOACETIC ACIDS							
552 Extraction	Complete		EPA 552.2	4/14/25	W JCM	A	
Monochloroacetic Acid	< 5.0	ug/L	EPA 552.2	4/17/25	W DPD	A	
Monobromoacetic Acid	< 3.0	ug/L	EPA 552.2	4/17/25	W DPD	A	
Dichloroacetic Acid	22.3	ug/L	EPA 552.2	4/17/25	W DPD	A	
Trichloroacetic Acid	18.6	ug/L	EPA 552.2	4/17/25	W DPD	A	
Dibromoacetic Acid	< 3.0	ug/L	EPA 552.2	4/17/25	W DPD	A	
Total Haloacetic Acids	40.9	ug/L	EPA 552.2	4/17/25	W DPD	A	
Surrogate-DBPA	129	%	EPA 552.2	4/17/25	W DPD	A	

002 Site: 704 Main Street (Carl's Equipment)

Date Sampled: 4/3/25 Time: 9:45

Facility ID: DS001 Smp Pt: TH001 Categ: GE Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual
TRihalOMETHANES							
Chloroform	64.0	ug/L	EPA 524.2	4/11/25	W EEP	A	
Bromodichloromethane	2.4	ug/L	EPA 524.2	4/11/25	W EEP	A	
Dibromochloromethane	< 0.5	ug/L	EPA 524.2	4/11/25	W EEP	A	
Bromoform	< 0.5	ug/L	EPA 524.2	4/11/25	W EEP	A	
Total Trihalomethanes	66.4	ug/L	EPA 524.2	4/11/25	W EEP	A	
Surr. 1 (4-Bromofluorobenzene)	100	%	EPA 524.2	4/11/25	W EEP	A	
Surr. 2 (1,2-Dichlorobenzene d4)	102	%	EPA 524.2	4/11/25	W EEP	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The E.P.A. regulates Trihalomethane & Haloacetic Acid levels. Testing is required quarterly. Contaminate levels are measured in parts per billion.